

STÅLPROFIL CONEPT SP 600

Stålprofilsystem SP 6000, SP 96000

Window partition

Holder/Issued to

Stålprofil PK AB

Kärrastrandsvägen 126, SE-451 76 Uddevalla, Sweden

Organisation number: 556303-4346

Phone: +46 522-64 68 70, Fax: +46 522-120 46

E-mail: info@stalprofil.se , Web: www.stalprofil.se

Product description

STÅLPROFIL CONCEPT SP 600

Stålprofilsystem SP 6000 or SP 96000, window partition of steel or stainless steel, max. size BxH 10000x3000 mm, E 30 / EI 15.

Intended use

Fire separating, straight, window partitions for internal installation in buildings.

Trade name

STÅLPROFIL CONCEPT SP 600

Stålprofilsystem SP 6000, SP 96000

Approval

The products satisfy the requirements set forth in chapter 8, 4 § 2 PBL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of Boverket Building Regulations (BBR) issued by the National Board of Housing, Building and Planning.

Fire resistance class E 30 / EI 15

5:231

Associated documents

-

Control

Production control (FPC) is to be performed in accordance with instructions for control as set out in document 4-4731-B, dated 2020-04-09, audited by an independent inspection body.

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this approval. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this approval is based.

Type approval 0446/02 | 2020-05-13

RISE Research Institutes of Sweden AB | Certification
Box 857, SE-501 15 Borås, Sweden
Phone: +46 10-516 50 00
certifiering@ri.se | www.ri.se

2019-06-10



Manufacturer

Production to be carried out by manufacturers, approved by Stålprofil PK AB, for which a decision on production control has been issued in accordance with chapter 8, 22 and 23 § Planning- and building Act (2010:900), PBL.

Marking

The products are to be marked at the factory. The marking consists of a sign, label or text on every product supplied and includes:

Information about the manufacturer

The name of the manufacturer,
manufacturing place and number of
decision on production control
e.g. SP 6000

Product type designation

no./date

Consecutive manufacture no./date of production

0446/02

Type approval number

e.g. E 30

Fire resistance class

+

Boverket's registered trade mark

1002

RISE accreditation number

RISE

Certification body

according to control agreement

Inspection body

Basis for approval

Report no. P005056 from SP Technical Research Institute of Sweden. Report no. PGA 10610 from DBI.

Drawings according to list no. 4-4646-B, dated 2020-01-31.

Manufacturing instructions according to document no. 4-4679-B, dated 2020-04-08.

Comments

Customised drawings for each specific building project shall be produced by the manufacturer.

All relevant properties that can be verified in accordance with a harmonised standard or are verified in accordance with a European technical assessment shall be listed in a declaration of performance.

This approval supersedes the previous approval with the same number dated 2019-12-13.

Validity

Valid through 2025-05-12.

The validity of this approval expires when the characteristics included in this approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.



Signed by: Johan Åkesson
I am the author of this document
2020-05-13 11:22:29 +01:00

Johan Åkesson

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish text shall take precedence.