

REGISTRATION CERTIFICATE

Single and double leaf fire-resisting and/or smoke control
inward and outward opening internal steel door-sets

Produced by

Tammer OÜ

in the manufacturing plant at the below address
Väike- Paala 4, 11415 Tallinn, Estonia

In compliance with the requirements of the A-MARK scheme of factory production control (FPC) detailed in BM Certification Scheme Technical Document of Verification of FPC and classification of products with higher fire resistance requirements according to EN 13501-2:2016 and EN 16034:2014

Performance of products is stated in Appendix A, B, C, D and E

| Product name |
|--------------------------------|
| SMU101 - EI30, SMU201 - EI30 |
| SMU101 - EI60, SMU201 - EI60 |
| SMU102 - EI60, SMU202 - EI60 |
| SMU110 - EI120, SMU210 - EI120 |
| SMU103 - EI60 |

This certificate was first issued on December 7, 2015 and will remain valid until the date of expiry shown on this certificate provided that the test methods and/or factory production control requirements included in the above document, do not change and the manufacturing conditions in the plant are not modified significantly.



Certificate number:
TT-PRS-093
Date of initial certification:
December 7, 2015

Date of last issue:
October 20, 2022
Certificate expiry date:
December 6, 2025

Jānis Švirksts
Member of the board
BM Certification

BM Certification SIA, 15 Jūrkalnaes street, Riga, LV-1046, Latvia

This certificate remains the property of BM Certification SIA. Further clarification regarding the scope of the certificate and verification of the certificate is available through BM Certification SIA at the above address or at www.bmcertification.com